

POOLS AND HOT TUBS

REQUIRED ELECTRICAL INSPECTIONS BASED ON THE 2011 NEC PER ARTICLE 680

As we all know all new pools have required electrical inspections, this includes in-ground pools, above ground pools, spas, and hot tubs, which need to meet the requirements of **article 680** of the **2011 NEC**, and which must **PASS BEFORE** work proceeds in some instances. Following is a list of some of the common required inspections, some of which may be performed at the same time, which all pools must pass:

1. Bonding
2. Bonding grids
3. Perimeter bonding
4. Bonding and potting of lights
5. Bonding of rebar
6. Any additional boning
7. Trenches
8. Roughts
9. Finals

This is a guideline, and not all inclusive, but in an effort to keep jobs moving along and prevent unnecessary delays. If you require additional inspections please call and discuss if needed.

However, any work performed that can not be seen at time of inspection will not be approved, until which time the work has been **EXPOSED** and **PASSES** the required inspections. Failure to have inspections will result in a **Notice of Violation**.